C-49

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F6/DFS/MS/WZ/2026/ 607 Dated: - 02/07/2026

To,

The Authorized Signatory,
New Blocks Academic for stage-1 of Phase-II,
Delhi Technological University,
Bawana Road, Shahbad Daulatpur, Delhi-110042.

Sub.: - Regarding renewal of Fire Safety Certificate in respect New Blocks Academic for stage-1 of Phase-II, Delhi Technological University, Bawana Road, Shahbad Daulatpur, Delhi-110042.

Sir,

This has reference to DFS online portal application no. 52026052903263 on the subject cited above. In this connection, it is to inform you that the said building was re-inspected by the officer concerned of this department on 15/06/2026 in the presence of Sh. Pardeep Yadav, A.E. Electric. During inspection, it was observed that the above said building is comprised of AB-3 & AB-4, Academic Interconnected Blocks – LGF/B+G+08 Upper Floors. After inspection, the following shortcoming were observed: -

1. Smoke Management Systems found not integrated with fire panel system in basement.
2. Automatic sprinkler system found non-functional.
3. Fire pumps found non-functional.

In view of the above shortcomings, the application for renewal of Fire Safety Certificate cannot be considered at this stage & **rejected.** The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

01/07/26

(S.K. Dua)
Chief Fire Officer
Delhi Fire Service