C-42

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**

No F.6/DFS/MS/EH/SZ/2026/ 584 Dated: 29/06/2026

## FIRE SAFETY CERTIFICATE

Certified that M/s Tamil Express Kitchen Pvt. located at M-4, Second Floor, Part-2, South Extension, New Delhi-110049, building comprised of basement, stilt, ground + 02 upper floors. Owned/Occupied by a unit of Tamil Express Kitchen Private Limited, was earlier issued Fire Safety Certificate by this department vide letter no F.6/DFS/MS/EH/SZ/2023/333 dated-09/11/2023. The premises was re-inspected by the officer concerned of this department on 16/06/2026 in the presence Sh. Kaushal kumar singh and found that the said premise have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules,2010 and that the premise is fit for occupancy class "Group-D" "Assembly Building"(Restaurant at 2nd floor only) with effect from 29/06/2026 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010. Conditions mentioned below.

Issued on 29/06/2026 at New Delhi by.

25/6/26

(A.K. Malik)
Chief Fire Officer

Copy to:

1. The Commissioner MCD, Civic Centre, Minto Road, New Delhi- 110002. - to ensure the occupancy as detailed above & deviation in construction if any.
2. The authorized signatory, M/s Tamil Express Kitchen Pvt. (A unit of Tamil Express Kitchen Private Limited) located at M-4, Second Floor, Part-2, South Extension, New Delhi-110049. (Online Portal ID No. 2026052607484 dated-26/05/2026)

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to nonfunctional fire safety measure shall be at the responsibility of the management/occupier.
3. The trained firefighting staff should be available round the clock.
4. Any deviation with regard to the construction, electrical installation, lift, setback area etc., shall be verified by the concerned sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape such as exit, corridor, passageway, etc., shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.
9. Basement shall be used as per bylaws strictly.

N/16

## INSPECTION REPORT

| | |
|---|---|
| 1. Name & address of the building | M/s Tamil Express Kitchen Pvt. (A unit of Tamil Express Kitchen Private Limited) located at M-4, Second Floor, Part-2, South Extension, New Delhi-110049. |
| 2. Type of Occupancy | "Group-D"Assembly Building. (Eating House), building comprised of basement , stilt, ground + 02 upper floors. |
| 3. Type of Case | Renewal |
| 4. Details of Previous NOC | F.6/DFS/MS/EH/SZ/2023/333 dated-09/11/2023 |
| 5. Fire Safety directives letter No | NBC (Part-IV) |
| 6. Date of inspection | 16/06/2026 |
| 7. Name of Inspecting Officer | Sh. Sarabjeet Singh ADO (BCP) |
| 8. Name and designation of officers From the building side | Mr. Kaushal Kumar Singh |
| 9. Year of Construction | 2012(As per online application) |
| 10. Applicant's letter No. | Online-ID No – 2026052607484 dated-26/05/2026 |

| S. No | Minimum Standards on fire prevention and fire safety U/R 33 | Required as per Rule 35(6) of DFS Rule 2010 | Provided at site | Remarks MR/NMR |
|---|---|---|---|---|
| 1. | **Access to building** | | | |
| | • Road width | 12m | 12m | MR |
| | • Gate width | NA | NA | NA |
| | • Width of internal road | NA | NA | NA |
| 2. | **Number, Width, Type & Arrangement of Exits** | | | |
| | **a. Number of staircases** | | | |
| | • Upper Floors | 02 Nos. | 02 Nos. | MR |
| | • Basements | NA | NA | NA |
| | **b. Width of staircases** | | | |
| | • Upper Floor | 1.50m each | 1.50m each | MR |
| | • Basements | NA | NA | NA |
| | **c. Protection of exits** | | | |
| | • Fire check door | NA | NA | NA |
| | • Pressurization | NA | NA | NA |
| | **d. No. of continuous staircases to terrace** | 01 nos. | 02 nos. | MR |
| | **e. Width of Corridor** | NA | NA | NA |
| | **f. Door Size** | 02m & 1.5m | 02m & 1.5m | MR |
| 3. | **Compartmentation** | | | |
| | a) Fire check door | NA | NA | NA |
| | b) Sealing of electrical shafts | NA | NA | NA |
| | c) Fire Rating of shaft door | NA | NA | NA |
| | d) Water Curtain | NA | NA | NA |
| | e) Fire Dampers | NA | NA | NA |
| 4. | **Smoke Management System** | | | |
| | a) Basements | NA | NA | NA |
| | b) Upper floors | Required | Provided | MR |
| 5. | **Fire Extinguishers** | | | |
| | a) Total numbers | 06 nos. | 06 nos. | MR |
| | b) Types | ABC/$CO_2$ | ABC&$CO_2$ | MR |
| | c) IS marking | ISI marked | Provided | MR |

| | | | | |
|---|---|---|---|---|
| **6.** | **First-Aid Hose Reels** | | | |
| | a) Total numbers on each floor | 01 nos. | Provided | MR |
| | b) Length of hose reel hose | 30mm | Provided | MR |
| | c) Nozzle diameter | 05m | Provided | MR |
| **7.** | **Automatic fire detection and alarming system** | | | |
| | a) Type of detectors | NA | NA | NA |
| | b) Location of Main Panel | NA | NA | NA |
| | c) Location of Repeater Panel | NA | NA | NA |
| | d) Alternate source of power | NA | NA | NA |
| | e) Hooters' Location | NA | NA | NA |
| **8.** | **MOEFA** | Required | Provided | MR |
| **9.** | **Public Address System** | NA | NA | NA |
| **10.** | **Automatic Sprinkler System** | | | |
| | a) Basement | NA | NA | NA |
| | b) Ground & Upper Floors | NA | NA | NA |
| | c) Sprinkler above false ceiling | NA | NA | NA |
| **11.** | **Internal Hydrants** | | | |
| | a) Size of riser/down-comer | 100mm | Provided | MR |
| | b) Number of hydrants per floor | 01nos. | Provided | MR |
| | c) Hose Box | 01nos. | Provided | MR |
| **12.** | **Yard Hydrants** | | | |
| | a) Total number of hydrants | NA | NA | NA |
| | b) Hose Box | NA | NA | NA |
| **13.** | **Pumping Arrangements** | | | |
| | • Ground Level | | | |
| | ➢ Discharge of main Pump | NA | NA | NA |
| | ➢ Head of Main pump | NA | NA | NA |
| | ➢ Number of main pumps | NA | NA | NA |
| | ➢ Jockey Pump out put | NA | NA | NA |
| | ➢ Jockey pump head | NA | NA | NA |
| | ➢ Standby Pump out put | NA | NA | NA |
| | ➢ Standby Pump Head | NA | NA | NA |
| | ➢ Auto Starting/Manual Stopping | NA | NA | NA |
| | ➢ Pump House Access | NA | NA | NA |
| | Terrace level | | | |
| | ➢ Discharge of pump | 450 LPM | 1620 & 180 LPM | MR |
| | ➢ Head of the pump | 40m | Provided | MR |
| | ➢ Power Supply | Required | Provided | MR |
| | ➢ Auto Starting of pump | Required | Provided | MR |
| **14.** | **Captive Water Storage for firefighting** | | | |
| | • Underground tank capacity | NA | NA | NA |
| | ➢ Draw-off connection | NA | NA | NA |
| | ➢ Fire service inlet | NA | NA | NA |
| | ➢ Access to tank | NA | NA | NA |
| | • Overhead Tank capacity | 10,000 ltrs. | 40,000 ltrs. | MR |
| **15.** | **Exit Signage.** | Required | Provided | MR |
| **16.** | **Provision of Lifts** | | | |
| | a) Pressurization of Lift Shaft | NA | NA | NA |
| | b) Pressurization of Lift lobby | NA | NA | NA |
| | c) Communication In lift Car | NA | NA | NA |
| | d) Fireman's Grounding Switch | NA | NA | NA |
| | e) Lift Signage | NA | NA | NA |

| | | | | |
|---|---|---|---|---|
| **17.** | **Standby power supply** | Required | Provided | MR |
| **18.** | **Refuge Area.** | | | |
| | a) Total Area | NA | NA | NA |
| | b) Location | NA | NA | NA |
| **19.** | **Fire Control Room** | | | |
| | a) Detector System | NA | NA | NA |
| | b) Flow Switch Panel | NA | NA | NA |
| | c) PA System Panel | NA | NA | NA |
| | d) Battery backup | NA | NA | NA |
| | e) Building Floor Plans | NA | NA | NA |
| **20.** | **Special Fire Protection System for Protection of special Risks, if any:** | NA | NA | NA |

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F.6/DFS/MS/EH/SZ/2023/333 dated-09/11/2023, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.Accordingly, DFA is put up for approval and signatures please.

**Last Date of Disposal- 26/06/2026**

17/6/2024

Name- Sarabjeet Singh
Designation – ADO(Mal. Ngr.)

DO (SD)

24/6/24
Ravinder Singh

CFO(SZ)

24/6/24
A.K. MALIK

Principal Director

CFO to Secretary.

23/06/24

CFO(SZ)

24/6/24
A.K. MALIK

DDO(SD)

25/6/24

ADO/MN

N/19

Ref. from pre-page N/18

Sir, R-T is put up for your perusal & obj. plz.

25/6/2026
Sarabjeet Singh

CRO(S12)

28/6/26
A.K. MALIK

M.S. Cell

Uploaded
30/6/26