C131

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**

No F.6/DFS/MS/GH/SZ/2026/ 619 Dated: 07/07/2026

## FIRE SAFETY CERTIFICATE

Certified that the M/s Conclave Executive, located at CC-22, Kalakji, New Delhi- 110065, comprise of basement, ground plus three upper floors, having (Ground Floor (Reception), 1st Floor (07 Guest Rooms), 2nd Floor (09 Guest Rooms) & 3rd Floor (09 Guest Rooms) (Total -25 Guest Rooms), owned/occupied by Libra Hotels Private Limited, was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/GH/2023/SZ/53 dated 27/02/2023. The premises was re-inspected by the officer concerned of this department on 23/06/2026 in the presence of Mr. George V.D. (Manager) and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with the Rule 33 of the Delhi Fire Service Rules 2010, and that the premises is fit for **(Ground Floor (Reception), 1st Floor (07 Guest Rooms), 2nd Floor (09 Guest Rooms) & 3rd Floor (09 Guest Rooms) (Total -25 Guest Rooms)**, occupancy Class "Residential & Lodging", Group-A" (Guest House) with effect from 07/07/2026 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010. Conditions mentioned below.

Issued on 07/07/2026 at New Delhi by.

7/7/26

(A.K. Malik)
Chief Fire Officer

Copy to:

1. The Commissioner MCD, Civic Centre, Minto Road, New Delhi- 110002. - to ensure the occupancy as detailed above & deviation in construction if any.
2. The authorized signatory, M/s Conclave Executive, located at CC-22, Kalakji, New Delhi- 110065. (Online Portal ID No. 2026061008633 dated 10/06/2026)

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to nonfunctional fire safety measure shall be at the responsibility of the management/occupier.
3. The trained firefighting staff should be available round the clock.
4. Any deviation with regard to the construction, electrical installation, lift, setback area etc., shall be verified by the concerned sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape such as exit, corridor, passageway, etc., shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.
9. Basement shall be used as per building bylaws strictly.

# INSPECTION REPORT

| | |
|---|---|
| 1. Name & address of the building | M/s Conclave Executive, located at CC-22, Kalakji, New Delhi- 110065. |
| 2. Type of Occupancy | Residential & Loding (Guest House), comprised of basement, ground, 1st, 2nd & 3rd floor. (ground floor-reception, 1st floor-07guest rooms, 2nd to 3rd floor-09 guest rooms each, total-25 guest rooms) |
| 3. Type of Case | Renewal |
| 4. Details of previous NOC | F6/DFS/MS/GH/2023/SZ/53 dated 27/02/2023 |
| 5. Fire Safety directives letter No | Nil |
| 6. Date of inspection | 23/06/2026 |
| 7. Name of the Inspecting Officers | Sarabjeet Singh ADO (Malviya Nagar) |
| 8. Name and designation of officers from the building side | Mr. George V.D. (Manager) |
| 9. Year of Construction | 2001 (As per online Portal) |
| 10. Applicant's letter No. | Online Application ID No. 2026061008633 dated 10/06/2026 |

| S. No. | Minimum Standards on fire prevention and fire safety U/R 33 | Required as per Rule 35(6) of DFS Rule 2010 | Provided at site | Remarks MR/NMR |
|---|---|---|---|---|
| 1 | **Access to building** | | | |
| | • Road width | 12m | 12m | MR |
| | • Gate width | NA | NA | NA |
| | • Width of internal road | NA | NA | NA |
| 2 | **Number, Width, Type & Arrangement of Exits** | | | |
| | a. Number of staircases | | | |
| | • Upper Floors | 02 Required | Provided | MR |
| | • Basements | 01 | Provided | MR |
| | b. Width of staircases | | | |
| | • Upper Floors | 1.25m | 1.25m & 1.0m | MR (old case) |
| | • Basements | 1.25m | 1.25m | MR (old case) |
| | c. Protection of exits | | | |
| | • Fire check door | Required | Provided | MR |
| | Pressurization | Required | Provided | MR |
| | d. No. of continuous staircases to terrace | 01 Required | Provided | MR |
| | e. Width of Corridor | NA | NA | NA |
| | f. Door Size | 1.0m | 1.0m (final exit) | MR |
| 3 | **Compartmentation.** | | | |
| | • Fire check door | NA | NA | NA |
| | • Sealing of electrical shafts | NA | NA | NA |
| | • Fire Rating of shaft door | NA | NA | NA |
| | • Water Curtain | NA | NA | NA |
| | • Fire Dampers | NA | NA | NA |
| 4 | **Smoke Management System.** | | | |
| | • Basements | Required | Exhaust Fan Provided | MR |
| | • Upper floors | Required | Exhaust Fan Provided | MR |
| 5 | **Fire Extinguishers** | | | |
| | • Total numbers | 15 Nos. | Provided | MR |
| | • Types | $CO_2$, ABC type | ABC & CO2 | MR |
| | • IS marking | ISI marked | Provided | MR |

| | | | | | |
|---|---|---|---|---|---|
| | • Total numbers on each floor | 01 | | Provided | MR |
| | • Length of hose reel hose | 30mtr | | Provided | MR |
| | • Nozzle diameter | 5mm | | Provided | MR |
| 7 | **Automatic fire detection and alarming system.** | | | | |
| | • Type of detectors | CO type | | Provided | MR |
| | • Location of main panel | Required | | Provided | MR |
| | • Location of Repeater Panel | NA | | NA | NA |
| | • Alternate source of power | Required | | Provided | MR |
| | • Hooters' Location | Required | | Provided | MR |
| 8 | **MOEFA** | Required | | Provided | MR |
| 9 | **Public Address System.** | Required | | Provided | MR |
| 10 | **Automatic Sprinkler System.** | | | | |
| | • Basement | Required | | Provided | MR |
| | • Upper Floor | NA | | NA | NA |
| | Sprinkler above false ceiling | NA | | NA | NA |
| 11 | **Internal Hydrants** | | | | |
| | • Size of riser/down-comer | NA | | NA | NA |
| | • Number of hydrants per floor | NA | | NA | NA |
| | • Hose Box | NA | | NA | NA |
| 12 | **Yard Hydrants.** | | | | |
| | • Total number of hydrants | NA | | NA | NA |
| | • Hose Box | NA | | NA | NA |
| 13 | **Pumping Arrangements.** | | | | |
| | Ground Level | | | | |
| | ➢ Discharge of main Pump | NA | | NA | NA |
| | ➢ Head of Main pump | NA | | NA | NA |
| | ➢ Number of main pumps | NA | | NA | NA |
| | ➢ Jockey Pump out put | NA | | NA | NA |
| | ➢ Jockey pump head | NA | | NA | NA |
| | ➢ Standby Pump out put | NA | | NA | NA |
| | ➢ Standby Pump Head | NA | | NA | NA |
| | ➢ Auto Starting/ Manual stopping | NA | | NA | NA |
| | ➢ Pump House Access | | | | |
| | • Terrace level | | | | |
| | ➢ Discharge of pump | 450 LPM | | 450LPM at G.F. | MR(Old Case) |
| | ➢ Head of the pump | 35m | | Provided | MR |
| | ➢ Power Supply | Required | | Provided | MR |
| | ➢ Auto Starting of pump | Required | | Provided | MR |
| 14 | **Captive Water Storage for fire fighting.** | | | | |
| | • Underground tank capacity | NA | | NA | NA |
| | ➢ Draw-off connection | NA | | NA | NA |
| | ➢ Fire service inlet | Required | | Provided | MR |
| | ➢ Access to tank | NA | | NA | NA |
| | • Overhead Tank capacity | 10,000ltrs | | Provided | MR |
| 15 | **Exit Signage.** | Required | | Provided | MR |

| | | | | |
|---|---|---|---|---|
| | • Pressurization of Lift Shaft | NA | NA | NA |
| | • Pressurization of Lift Lobby | NA | NA | NA |
| | • Communication In lift Car | NA | NA | NA |
| | • Fireman's Grounding Switch | Required | Provided | MR |
| | • Lift Signage | Required | Provided | MR |
| 17 | **Standby power supply** | Required | Provided (DG set) | MR |
| 18 | **Refuge Area.** | | | |
| | • Total Area | NA | NA | NA |
| | • Location | NA | NA | NA |
| 19 | **Fire Control Room** | | | |
| | • Detector System Panel | NA | NA | NA |
| | • Flow Switch Panel | NA | NA | NA |
| | • PA System Panel | NA | NA | NA |
| | • Batter backup | NA | NA | NA |
| | • Building Floor Plans | NA | NA | NA |
| 20 | Special Fire Protection Systems for Protection of special Risks, if any: | NA | NA | NA |

The fire protection systems provided in the building were checked randomly and found functional at the time of inspection.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules, the NOC vide letter no F6/DFS/MS/GH/2023/SZ/53 dated 27/02/2023, renewal under the rule 37 of the Delhi Fire Service rules 2010 is recommended.

25/6/26

Signature of the Inspecting Officer
Name: Sarabjeet Singh
Designation: ADO(Malviya Nagar.)

DO (SD)

25/6/26

Ravinder Singh

CFO(S2)

30/6/26
A.K. MALIK

CFO AO Hqrs.

CFO (S2)

30/6/26
A.K. MALIK

Addl CP Ref. from pre-page N44

Sir, R.T is put up for your kind perusal &

Dy. P/S.I

06/7/2026
Sarab Jeet Singh

CRO(SIZ)

A.K. MALIK

M.S Cell
Uploaded
07/07/26