C-54

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

NO.F.6/DFS/MS/School/2026/ 601 Dated: 30/06/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
Dr. SPM Civic Center, Minto Road,
New Delhi–110002.

Sub: - Application regarding renewal of FSC/NOC in r/o **Vanasthali Public School** located at **Ghevra – Nizampur Road, Delhi - 110081.**

Sir,

This has a reference to online ID- 52026050802781 on the subject cited above. In this connection, it is to inform you that the premise was visited by the officer concerned of this department on 15/06/2026 in the presence of Smt. Sangeeta Sharma (Principal). During course of inspection, the shortcomings observed are as below: -

1. Hose reel provided but found non- functional.
2. Terrace pump provided but found non- functional.
3. Auto starting of terrace pump found non-functional.
4. Overhead tank capacity of 2000 ltrs provided against the requirement of 10,000 ltrs provided.

In view of the above, application for fire safety certificate is rejected. You are requested to rectify the above shortcomings under intimation to this department for further action in the matter. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of owner/occupier of the establishment. The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

29/6/26
(Dr. S. K. Tomar)
Chief Fire Officer
Delhi Fire Service

Copy to: -

The Principal,
Vanasthali Public School,
located at Ghevra – Nizampur Road, Delhi - 110081