C-83

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/2026/GH/664 Dated: 09/07/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
Dr. S.P.M. Civic Centre, JL Nehru Marg,
New Delhi -110002.

**Sub:** Renewal of FSC in r/o M/s Vivah Residency Guest House, located at Property No. 25, Bhera Enclave, Paschim Vihar, New Delhi-110087.

Sir,

This has reference to online application no. 2026060908512 dated 09/06/2026 on the subject cited above. In this connection, it is to inform you that the above said building was re-inspected by the officer concerned of this department on 22.06.2026 in the presence of Sh. Harish (Owner) to check the compliance of shortcomings issued by this department vide letter no. F.6/DFS/MS/GH/2026/WZ/550 dated 04.06.2026 (copy enclosed).

During inspection, it has been observed that the shortcomings issued by this department vide above said letter has not been rectified yet.

In view of the above, the application for renewal of Fire Safety Certificate cannot be considered at this stage & rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/statutory Authority may take suitable necessary action as deemed fit.

Yours Faithfully

Encl: As above.

08/07/26

(S. K. Dua)
Chief Fire Officer
Delhi Fire Service

Copy to:-

1. MCD Portal Id-2026060908512 dated 09/06/2026.

C-82
C-75-

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No:F.6/DFS/MS/GH/2026/WZ/530 Dated: 04/06/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
S.P.M. Civic Centre, J.L. Nehru Marg,
New Delhi 110002.

Sub: - Regarding renewal of Fire Safety Certificate in r/o M/s Vivah Residency Guest House located at Property No. 25, Bhera Enclave, Paschim Vihar, New Delhi- 110087.

Sir,

This has reference to online application received through MCD portal vide ID- 2026051206696 on the subject cited above. In this connection, it is to inform you that the above said residential building was re-inspected by officer concerned of this department on 25/05/2026 to see the compliance of requisite fire safety measures. Mr. Gaurav was present at the time of inspection. Following shortcoming were observed at the time of inspection.

1. Fire Check door found removed at some places.
2. First aid hose reel nozzle found missing at some places.
3. Carbon monoxide detectors found removed at some places.
4. MOEFA found provided but not functional.
5. P.A. System found provided but not functional.
6. Internal hydrant found provided but not functional.
7. Terrace level pump found provided but not functional.
8. Exit signage's found removed at some places.

In view of above, the application for renewal of Fire Safety Certificate is not considered at this stage & rejected. The occupancy of the building/ premises in absence of requisites fire safety measures shall be at the risk and liabilities of the owner/ occupier.

Yours Faithfully

02/06/26

**S.K. Dua**
**Chief Fire Officer**
**Delhi Fire Service**

Copy to:-

1. M/s Vivah Residency Guest House located at Property No. 25, Bhera Enclave, Paschim Vihar, New Delhi- 110087
2. MCD Portal ID No. 2026051206699.