C-57

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

No. F.6/DFS/MS/School/2026/SZ/ 96 Dated: 09/07/2026

FIRE SAFETY CERTIFICATE

Certified that the Jinvani Bharti Public School located at Sector- 04, Dwarka, New Delhi-110078, comprised of small basement (storage), ground floor plus three upper floors, was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/2023/555 dated 17.08.2023. The school building was re- inspected by the officer concerned of this department on dated 16.06.2026 in the presence of Mr. Pankaj Jain, and found that the school building have deemed complied the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building/premises (ground plus three upper floors) is fit for occupancy class "Educational Building" w.e.f. 09/07/26 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on 09/07/2026 at New Delhi by.

08/07/26

(S.K. Dua)
Chief Fire Officer
West Zone

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.
2. The Principal, Jinvani Bharti Public School located at Sector- 04, Dwarka, New Delhi- 78.
3. The Director, Delhi Development Authority, Vikas Sadan, INA, New Delhi-110023.

: - for information regarding use of basement.

Conditions for the validity of fire safety certificate: -

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Presently basement used only for storage purpose.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N/18

INSPECTION REPORT

1. Name & address of the building : Jinvani Bharti Public School School at Sector- 04 Dwarka, New Delhi- 110078.
2. Building comprised of : Ground plus three upper floors with small basement.
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC : F.6/DFS/MS/School/2023/555 dated 17.08.2023
6. Fire Safety directives letter No : NBC Part- IV letter dated 24.11.2004
7. Date of inspection : 16.06.2026
8. Name of Inspecting Officer : A.D.O. R.K.Yadav
9. Name and designation of officers From the building side : Sh. Pankaj Jain
10. Year of Construction : 2006
11. Applicant's letter No. : etl.mcdonline Application No. 52026060103319

Sr. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirements as per FSC dated 17.08.2023	Provided at site	Remarks MR/NMR
1.	**Access to building**			
	• Road width	6.0 m	Provided	M/R
	• Gate width	4.5 m	Provided	MR
	• Width of internal road	N/A	N/A	N/A
2.	**Number, Width, Type & Arrangement of Exits**			
	a. Number of staircases			
	• Upper Floors	03 No's	Provided	M/R
	• Basements	02 No's	02 No's	M/R
	b. Width of staircases			
	• Upper Floor	1.50 m each	1.70 m & 1.30 m (02 nos.)	MR, old case
	• Basements		170 & 1.30 m	MR, old case
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	Required - 03	03 nos.	M/R
	e. Width of Corridor	1.25 m	1.50 m	M/R
	f. Door Size	1.0 m	1.0 m	M/R
3.	**Compartmentation**			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	**Smoke Management System**			
	• Basements	30 ACPH	Provided	MR
	• Upper floors	12 ACPH	Natural ventilation	M/R
5.	**Fire Extinguishers**			
	• Total numbers	46 no's	Provided	M/R
	• Types	ABC/CO_2 type	Provided	M/R
	• IS marking	ISI marked	Provided	M/R
6.	**First-Aid Hose Ree**			
	• Total numbers at each floor	02 nos.	Provided	M/R
	• Length of hose reel hose	30 M	Provided	M/R
	• Nozzle diameter	5 mm	Provided	M/R

	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	**MOEFA**	N/A	N/A	N/A
9.	**Public Address System**	Required	Provided	MR
10.	**Automatic Sprinkler System**			
	• Basement	Required	Provided	MR
	• Ground Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	**Internal Hydrants**			
	• Size of riser/down-comer	100 mm	Provided	MR
	• Number of hydrants per floor	02 Nos.	03 Nos.	MR
	• Hose Box	Required	Provided	MR
12.	**Yard Hydrants**			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	**Pumping Arrangements**			
	• Ground Level			
	➢ Discharge of main Pump	N/A	N/A	N/A
	➢ Head of Main pump	N/A	N/A	N/A
	➢ Number of main pumps	N/A	N/A	N/A
	➢ Jockey Pump out put	N/A	N/A	N/A
	➢ Jockey pump head	N/A	N/A	N/A
	➢ Standby Pump out put	N/A	N/A	N/A
	➢ Standby Pump Head	N/A	N/A	N/A
	➢ Auto Starting/Manual Stopping	N/A	N/A	N/A
	➢ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➢ Discharge of pump	900 LPM	2 × 450 LPM & 180 LPM	MR
	➢ Head of the pump	40 m.	Provided	MR
	➢ Power Supply	Required	Provided	MR
	➢ Auto Starting of pump	Required	Provided	MR
14.	**Captive Water Storage for fire fighting**			
	• Underground tank capacity	~~N/A~~ 50000 Ltrs	50,000 ltrs.	MR
	➢ Draw-off connection	N/A	Provided	N/A
	➢ Fire service inlet	N/A	Provided	N/A
	➢ Access to tank	N/A	Provided	N/A
	• Overhead Tank capacity	10,000 ltrs	Provided	MR
15.	**Exit Signage.**	Required	Provided	MR
16.	**Provision of Lifts.**		**No Lift**	
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A

N/20

18.	**Refuge Area.**			
	➢ Total Area	N/A	N/A	N/A
	➢ Location	N/A	N/A	N/A
19.	**Fire Control Room**			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	**Special Fire Protection System for Protection of special Risks, if any:**	Required	Co2 type Fire extinguisher provided near electric panel	MR

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Note: - As per affidavit submitted by school management (placed at C- 46) that the school building comprised of basement, ground plus three upper floors, using basement only for storage purpose, any other activity for students and teacher is not being carried out in basement..

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the Fire Safety Certificate issued vide letter No. F.6/DFS/MS/School/2023/555 dated 17.08.2023, **is recommended to be renewed** under rule 37, of the Delhi Fire Service Rules, 2010.

18/6/2026

Signature of the Inspecting Officer
Name:-R.K. Yadav
Designation: - ADO (DWK)

DO (SW)

20/6/26

DCFO (WZ) 23/06/2025

CFO (WZ) - On Leave

Principal Director

As [illegible]

CFO to Assure.

F.T. please. 2/2

CFO (WZ)

06/07/26

ADO (DWK)

N/20

FT letter is put up for sign please

7/7/2026

CFO(W2)

08/07/26

F.P. wing