GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F6/DFS/MS/School/WZ/2026/95 Dated: 08/07/2026

FIRE SAFETY CERTIFICATE

Certified that the **Good Samaritan School** located at Issapur, (P.O. Ojwa), Dhansa Road, New Delhi – 110073building comprised of ground floor only, owned / occupied by **Good Samaritan School** was earlier issued Fire Safety Certificate vide letter No. F6/DFS/MS/School/2023/SZ/33 dated 17/01/2023. The School was re-inspected by the officer concerned of this department on 30/06/2026 in presence of Mrs. Monika Thomson (Principal)and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No.262 – 362 dated 17.01.2005 issued by the Director of Education and that the building/premises (**Ground floor only**) is fit for occupancy class "Educational Building" (Group-B) with effect from 08/07/2026 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010 & also conditions printed bellow.

Issued on 08/07/2026 **at New Delhi by.**

07/07/26
(S. K Dua)
Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Director of Education, GNCT of Delhi, Old Secretariat, Delhi – 110054.
2. The Principal, Good Samaritan School at Issapur, (P.O. Ojwa), Dhansa Road, New Delhi – 110073

Conditions for the validity of Fire Safety Certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the firefighting equipment's shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc. may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT					
01.	Name & address of the building		Good Samaritan School located at Issapur, (P.O. Ojwa), Dhansa Road, New Delhi – 110073.		
02.	Building is comprised of		Ground floor only		
03.	Type of occupancy		Educational Building		
04.	Type of case		Renewal Case		
05.	Details of previous FSC		F6/DFS/MS/School/2023/SZ/33 dated 17/01/2023		
06.	Fire safety directives letter no.		DEO Circular No. 262 – 362 dated 17/01.2005		
07.	Date of inspection		30.06.2026.		
08.	Name of the inspecting officers		Yashwant Singh Meena, ADO/Najafgarh		
09.	Name of the designation of officer from the building side		Mrs. Monika Thomson (Principal)		
10.	Year of construction		Before 2010		
11.	Applicant's letter no.		Online Application No. 52026061503686		
S.No	**Minimum standard of fire prevention and fire safety U/R 33**		**Dir. Of Edu. Cire. Dt. 17.01.2005**	**Provided at site**	**Remarks MR/NMR**
01.	**Access to Building:**				
	A	Road width	Accessible (6.0 meters)	5.0 meters.	MR **(Old Case)**
	B	Gate width	4.50 meters	Provided	MR
	C	Width of internal road	N/A	N/A	N/A
02.	**Number, Width, Type and Arrangement of Exits:**				
	A	Number of staircases			
	a	Upper floor	N/A	Ground floor only	N/A
	C	Basement	N/A	N/A	N/A
	B	Width of staircases			
	a	Upper floor	N/A	Ground floor only	N/A
	C	Basement	N/A	N/A	N/A
	C	Protection of exits			
	a	Fire check door	N/A	N/A	N/A
	b	Pressurization	N/A	N/A	N/A
	D	No. of continuous staircases to terrace	N/A	N/A	N/A
	E	Width of corridor	N/A	N/A	N/A
	F	Door size	1.0 meter	0.95 meters (Double Door)	MR **(Old Case)**
03.	**Compartmentation:**				
	A	Fire check door	N/A	N/A	N/A
	B	Sealing of electrical shafts	N/A	N/A	N/A
	C	Fire rating of shaft door	N/A	N/A	N/A
	D	Water curtain	N/A	N/A	N/A
	E	Fire dampers	N/A	N/A	N/A
04.	**Smoke Management System:**				
	A	Basement	N/A	N/A	N/A
	B	Upper floor	N/A	N/A	N/A

Good Samaritan School located at Issapur, (P.O. Ojwa), Dhansa Road, New Delhi – 110073

05.	**Fire Extinguisher:**				
	A	Total numbers	04 nos.	Provided	MR
	B	Types	ABC/CO_2	Provided	MR
	C	ISI marking	ISI Marked	Provided	MR
06.	**First-Aid-Hose Reel:**				
	A	Total numbers of each floor	N/A	N/A	N/A
	B	Length of hose reel hose	N/A	N/A	N/A
	C	Nozzle diameter	N/A	N/A	N/A
07.	**Automatic Fire Detection and Alarming System:**				
	A	Type of detectors	N/A	N/A	N/A
	B	Location of main panel	N/A	N/A	N/A
	C	Location of repeater panel	N/A	N/A	N/A
	D	Alternate source of power	N/A	N/A	N/A
	E	Hooters	N/A	N/A	N/A
08.	**MOEFA:**		N/A	N/A	N/A
09	**Public Address System:**		N/A	N/A	N/A
10.	**Automatic Sprinkler System:**				
	A	Basement	N/A	N/A	N/A
	B	Upper floor	N/A	N/A	N/A
	C	Sprinkler above false ceiling	N/A	N/A	N/A
11.	**Internal Hydrants:**				
	A	Size of riser/**down-comer**	N/A	N/A	N/A
	B	Number of hydrants per floor	N/A	N/A	N/A
	C	Hose box	N/A	N/A	N/A
12.	**Yard Hydrants:**				
	A	Total number of hydrants	N/A	N/A	N/A
	B	Hose box	N/A	N/A	N/A
13.	**Pumping Arrangements:**				
1	**Ground level**				
	A	Discharge of main pump	N/A	N/A	N/A
	B	Head of main pump	N/A	N/A	N/A
	C	Number of main pumps	N/A	N/A	N/A
	D	Jockey pump out put	N/A	N/A	N/A
	E	Jockey pump head	N/A	N/A	N/A
	F	Standby pump out put	N/A	N/A	N/A
	G	Standby pump head	N/A	N/A	N/A
	H	Auto starting /manual stopping	N/A	N/A	N/A
	I	Pump house access	N/A	N/A	N/A
2	**Terrace Level**				
	A	Discharge of pump	N/A	N/A	N/A
	B	Head of the pump	N/A	N/A	N/A
	C	Power supply	N/A	N/A	N/A
	D	Auto starting of pump	N/A	N/A	N/A

Good Samaritan School located at Issapur, (P.O. Ojwa), Dhansa Road, New Delhi – 110073

14.	**Captive Water Storage for Fire Fighting:**				
	A	Underground tank capacity	N/A	N/A	N/A
	B	Draw-off connection	N/A	N/A	N/A
	C	Fire service inlet	N/A	N/A	N/A
	D	Access to tank	N/A	N/A	N/A
	E	Overhead tank capacity	N/A	N/A	N/A
15.	**Exit Signage:**		N/A	N/A	N/A
16.	**Provision of Lifts:**				
	A	Pressurization of lift shaft	N/A	N/A	N/A
	B	Pressurization of lift lobby	N/A	N/A	N/A
	C	Communication in lift car	N/A	N/A	N/A
	D	Firemen's grounding switch	N/A	N/A	N/A
	E	Lift signage	N/A	N/A	N/A
17.	**Standby Power Supply:**		NA	N/A	N/A
18.	**Refuge Area:**				
	A	Total area	N/A	N/A	N/A
	B	Location	N/A	N/A	N/A
19.	**Fire Control Room:**				
	A	Detector system panel	N/A	N/A	N/A
	B	Flow switch panel	N/A	N/A	N/A
	C	PA system panel	N/A	N/A	N/A
	D	Battery backup	N/A	N/A	N/A
	E	Building floor plans	N/A	N/A	N/A
20.	**Special Fire Protection systems for protection of special Risks, if any:**		NA	N/A	N/A

The fire protection system was randomly checked and tested and was found functional at the time of inspection.

Keeping in view of the deemed compliance of minimum standards on fire prevention and fire safety measures as required under the Rules the Fire Safety Certificate issued vide letter no. F6/DFS/MS/School/2023/SZ/33 dated 17/01/2023 renewal under the Circular No. 262 – 362 dated 17.01.2005 is **recommended.**

01/7/2026

Signature of the Inspecting Officer
Name: - Yashwant Singh Meena
Designation: - ADO/Najafgarh

Dy. Chief Fire Officer (WZ) Disp. 98 Date 2/07/26 N/ Delhi Fire Service

D.O//SW

1/7/26

DFO (WZ)

02/07/2026

CFO (WZ)

02/07/26

Pr. Director

CFO to issue.

F.T. please. 3/7

CFO (WZ)

N/13

Sir.

F.T letter is Putup for Sign. Pleasy

7/7/2026

CFO/(WZ)

Liv
07/07/26

F.P. Wing