C 37

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/BANQ/SZ/2026/586 Dated: 29/06/2026

FIRE SAFETY CERTIFICATE

Certified that M/s. Gokul Garden Banquets Pvt. Ltd. located GF, WZ, 306-T, Data Ram Marg, Kh. No. 72/18/2, 19/3 & 23, Palam Colony, New Delhi- 110045, running at ground floor only in a building comprised of ground plus one upper floor, was granted FSC by this department vide letter No. F6/DFS/MS/SZ/2023/BNQT./21 dated 02.06.2023. The banquet hall was re-inspected by the officer concerned of this department on 09.06.2026 in the presence of Mr. Rajeev Solanki, and found that the said building have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Group D 'Assembly Building', **(for Ground Floor Only)** with effect from 29/06/2026 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued on 29/06/2026 at New Delhi.

29/06/26

(S.K. Dua)
Chief Fire Officer
West Zone

Copy to: -

The Commissioner, MCD, Delhi: **with a request to ensure the occupancy as detailed above and deviation, if any.**
(Online application Id 2026053007688 dated 02.06.2026)

Conditions for the validity of fire safety certificate: -

1. The FSC is issued for Banquet Hall running at ground floor only.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
3. The means of escape arrangements shall be kept unlocked & unobstructed for speedy evacuation of occupants in case of an emergency.
4. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
5. The trained staff should be available round the clock.
6. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
7. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N9

INSPECTION REPORT

1. Name & address of the building : M/s. Gokul Garden Banquets Pvt. Ltd. at GF, WZ, 306-T, Data Ram Marg, Kh. No. 72/18/2, 19/3 & 23, Palam Village, New Delhi- 45.
2. Type of Occupancy : Assembly (Banquet Hall)
3. Building Composition : The said banquet hall is running on ground floor of a Building Comprised of ground plus 01 upper floor.
4. Type of Case : Renewal
5. Details of previous FSC : F6/DFS/MS/SZ/2023/BNQT./21 dated 02.06.2023
6. Fire Safety directives letter No : F6/DFS/MS/BP/2023/95 dated 08.05.2023
7. Date of inspection : 09.06.2026
8. Name of the Inspecting Officers : R.K. Yadav, ADO (DWK)
9. Name and designation of officers from the building side : Sh. Rajeev Solanki
9. Year of Construction : 2004 (as per online application)
10. Applicant's letter No. : Id No. 2026053007688 dated 02.06.2026

Sr. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per FSC dt. 02.06.2023	Provided at site	Remarks MR/NMR
1	**Access to building**			
	• Road width	09 mts	Provided	MR
	• Gate width	05 mts	Directly accessible from road	MR
	• Width of internal road	N/A	N/A	N/A
2	**Number, Width, Type & Arrangement of Exits**			
	a. Number of staircases	-	-	-
	• Upper Floors	N/A	01 nos.	N/A
	• Basements	N/A	N/A	N/A
	b. Width of staircases	-	-	-
	• Upper Floors	N/A	N/A	N/A
	• Basements	N/A	N/A	N/A
	c. Protection of exits	-	-	-
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	N/A	N/A	N/A
	g. Width of Corridor	N/A	N/A	N/A
	h. Door Size	2.0 m	2.0 m (02 Nos.)	MR
3	**Compartmentation.**			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	**Smoke Management System.**			
	• Basements	N/A	N/A	N/A
	• Upper floors	12 a/c per hour	Provided	MR
5	**Fire Extinguishers**			
	• Total numbers	06 nos.	Provided	MR
	• Types	ABC & CO_2 type	ABC & CO_2 type	MR
	• IS marking	ISI marked	Provided	MR
6	**First-Aid Hose Reels.**			
	• Total numbers on each floor	02	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR

NTD

7	**Automatic fire detection and alarming system.**			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8	**MOEFA**	Required	Provided	MR
9	**Public Address System.**	N/A	N/A	N/A
10	**Automatic Sprinkler System.**			
	• Basement	N/A	N/A	N/A
	• Upper Floor / Ground Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11	**Internal Hydrants**			
	• Size of riser/down-comer	100 mm	Provided	MR
	• Number of hydrants per floor	02 No.	Provided	MR
	• Hose Box	02 No.	Provided	MR
12	**Yard Hydrants.**			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	**Pumping Arrangements.**			
	• Ground Level	---	---	---
	➢ Discharge of main Pump	N/A	N/A	N/A
	➢ Head of Main pump	N/A	N/A	N/A
	➢ Number of main pumps	N/A	N/A	N/A
	➢ Jockey Pump out put	N/A	N/A	N/A
	➢ Jockey pump head	N/A	N/A	N/A
	➢ Standby Pump out put	N/A	N/A	N/A
	➢ Standby Pump Head	N/A	N/A	N/A
	➢ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➢ Pump House Access	N/A	N/A	N/A
	• Terrace level	------	-------	--------
	➢ Discharge of pump	900 LPM	Provided	MR
	➢ Head of the pump	40 mts	Provided	MR
	➢ Power Supply	Required	Provided	MR
	➢ Auto Starting of pump	Required	Provided	MR
14	**Captive Water Storage for fire fighting.**			
	• Underground tank capacity	N/A	N/A	N/A
	➢ Draw-off connection	N/A	N/A	N/A
	➢ Fire service inlet	N/A	N/A	N/A
	➢ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	25,000 lts	Provided	MR
15	**Exit Signage.**	Required	Provided	MR
16	**Provision of Lifts. Provided but not commissioned**			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A

N/M

		Required	Provided	MR
17	**Standby power supply**			
18	**Refuge Area.**			
	➢ Total Area	N/A	N/A	N/A
	➢ Location	N/A	N/A	N/A
19	**Fire Control Room**			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were checked at random and found satisfactory at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F6/DFS/MS/SZ/2023/BNQT./21 dated 02.06.2023, **renewal under rule 37** of the Delhi Fire Service Rules 2010, **is recommended**.

12/06/2026

Signature of Inspecting Officer
Name: - R.K. Yadav
Designation: - ADO (DWK)

DO (SW)

15/6/26

RAJINDER ATWAL

DCFO (WZ)

18/06/2026

CFO (WZ)

18/06/26

Pr. Director

CFO to Dom.

18/06/26

CFO (WZ)

F.T. please.

M/12

FT letter is put up for sign please

24/03/2026

CFO(WZ)

29/06/26

F.P. wing

Uploaded
30/6/26