GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

Application ID. 52025112400091 **Dated: 11-12-2025**

SHORTCOMING(S)

With reference to your application ID **52025112400091** dated **11-12-2025** on the subject cited above, it is informed that officer concerned of this department inspected the **Industrial** at **Plot No. 377, FIE, Patparganj Industrial Area, Delhi 92** from fire safety point of view in presence of **Mr. Anil Jain** on dated **05/12/2025** During the course of inspection following observations were made:-

1. There is major addition/alternation at terrace and stilt floor respectively, effecting means of escape.
2. The width of the alternate staircase in the basement is not meeting the requirement.
3. The smoke management system in the basement & upper floor was found removed.

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

A. Nedunchezhiyan, IAS
Pr. Director

Copy to:-
1. Anil Jain , 213, Upper Ground Floor, Ram Vihar, Delhi, 110092
2. The Concerned Local/Statutory Authority –