GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

Application ID. 52025121100472 **Dated: 06-01-2026**

SHORTCOMING(S)

With reference to your application ID **52025121100472** dated **06-01-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **Handicapped Women Welfare Association** at **PSP Institutional Area, Madhuban Chowk, Rohini, Delhi-110085.** from fire safety point of view in presence of **Jeele Singh** on dated **14/12/2025** During the course of inspection following observations were made:-

1. Smoke ventilation in basement found removed.
2. Hose reel hose is provided but not functional.
3. Sprinklers system is provided in the basement but found not functional.
4. Internal hydrant is provided but not functional.
5. Terrace level fire pump capacity of 450 LPM is provided but not functional.
6. Terrace level fire water tank capacity of 3000 Ltr. is provided against the requirement of 5000 Ltr.
7. Passenger lift is required one lift lobby in basement or sealed by brick wall in case of emergency.
8. Firemen grounding switch is provided but not functional.

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

S.K.DUA
Dy.Chief Fire Officer

Copy to:-
1. Ms Sanjana Mittal , 66, Pocket C 3 1sti Floor, Sector 11 Rohini, Delhi, 110085
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.