GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

Application ID. 52025122000824 **Dated: 09-03-2026**

SHORTCOMING(S)

With reference to your application ID **52025122000824** dated **09-03-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **St. Krishna Bodh Public School** at **Plot No 147, 148 & 149, Mondoli Road, West Nathu Colony,Shahdara,Delhi 110093** from fire safety point of view in presence of **Nidhish Bharadwaj** on dated **30/12/2025** During the course of inspection following observations were made:-

Terrace pump capacity 220 lpm head 22 merter provided against the requirement of 450 lpm head 40 meter

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

Dr.S.K.Tomar
Dy.Chief Fire Officer

Copy to:-
1. Ashish Bhardwaj , House No.77, Vigyan Vihar, Vigyan vihar, East Delhi, 110092
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.