GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

Application ID. 52026010200027 **Dated: 10-03-2026**

SHORTCOMING(S)

With reference to your application ID **52026010200027** dated **10-03-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **Sarvodaya Co-Ed Senior Secondary School** at **B2 Block, Safdarjung Enclave, New Delhi - 110029** from fire safety point of view in presence of **Smt. Sangeeta Chauhan** on dated **27/02/2026** During the course of inspection following observations were made:-

1. Fire extinguishers are not provided.
2. First aid hose reels are found non functional.
3. Terrace pump is found non functional.
4. Auto starting of pump found non functional.

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

A.K.Malik
Dy.Chief Fire Officer

Copy to:-
1. Sangeeta Chauhan , CM SHRI SCHOOL , Safdarjung Enclave , Safdarjung Enc, New Delhi , 110029
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.