GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

Application ID. 52026010500072 **Dated: 22-05-2026**

SHORTCOMING(S)

With reference to your application ID **52026010500072** dated **22-05-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **Sarvodaya Kanya Vidyalaya** at **G.T.B. Nagar, Delhi-110009** from fire safety point of view in presence of **Smt. Sangeeta Batra** on dated **14/05/2026** During the course of inspection following observations were made:-

1. Fire extinguisher provided in the building found non-functional.
2. First-aid hose reel hose is provided but found non-functional and some nozzle are missing.
3. Terrace level fire fighting pump capacity of 450 LPM provided but found non-functional
4. Terrace level fire water tank capacity of 10,000 ltrs. is provided found empty.
5. Exit signage's found removed at strategic locations in the building

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

S.K.DUA
Chief Fire Officer

Copy to:-
1. MUNMUN , 246, GROUND FLOOR, INDRA VIHAR, DELHI, 110009
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.