GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

Application ID. 52026011300274 **Dated: 09-05-2026**

SHORTCOMING(S)

With reference to your application ID **52026011300274** dated **09-05-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **Amrit Co-OP Group Housing Society Ltd., Rashmi Apartment** at **Harsh Vihar, Pitampura, Delhi-110034.** from fire safety point of view in presence of **Mr. Kuldeep Care Taker** on dated **05/05/2026** During the course of inspection following observations were made:-

1.Fire check doors found removed.
2.P.A System found removed at some floor.
3.Hose boxes found without hose pipes.
4.Terrace level fire pump not found in auto mode.
5.Exit signage's found removed at some places.
6.P.A. System panel found removed.
7.Balconies found covered by metal railings and plastic/fiber sheets

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

S.K.DUA
Chief Fire Officer

Copy to:-
1. Ravinder Prakash Tyagi , F-2 RASHMI APARTMENTS, HARSH VIHAR, PITAMPURA, DELHI, 110034
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.