GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

Application ID. 52026011400291 **Dated: 19-05-2026**

SHORTCOMING(S)

With reference to your application ID **52026011400291** dated **19-05-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **Vasudha Education Society** at **G and JU Block, Pitam Pura, Delhi-110034** from fire safety point of view in presence of **Mrs. Anshoo Sath** on dated **06/05/2026** During the course of inspection following observations were made:-

1.Addition/ alteration found by adding two floors on existing G+1 building. Therefore, you are advised to forward your case through building sanctioning authority or submit approved/ as built plan from empanelled architect.

2.Fire protection system found provided but not in working condition.

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

S.K.DUA
Chief Fire Officer

Copy to:-
1. HARCHARAN SINGH , CD-158, PITAM PURA , SHALIMAR BAGH, DELHI, 110088
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.