GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

Application ID. 52026011500331 **Dated: 27-03-2026**

SHORTCOMING(S)

With reference to your application ID **52026011500331** dated **27-03-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **Retreat Water World (A Unit of Jingle Bell Amusement Park Pvt. Ltd.)** at **Alipur, Main G.T.K. Road, Delhi-110036** from fire safety point of view in presence of **Sh. Anil Bhardwaj & Sanjay Bhardwaj** on dated **06/02/2026** During the course of inspection following observations were made:-

1. First-Aid Hose Reels found removed.
2. MOEFA found removed.
3. Ground level fire pump found removed.
4. Underground tank of 50,000 ltrs capacity found very less in water level.
5. Exit signages found removed.
6. Standby power supply found removed.

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

S.K.DUA
Dy.Chief Fire Officer

Copy to:-
1. HUKUM CHAND DESHWAL , 8, SECTOR 6, , KARNAL, HARYANA, HARYANA, 132001
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.