GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

Application ID. 52026011900376 **Dated: 06-02-2026**

SHORTCOMING(S)

With reference to your application ID **52026011900376** dated **06-02-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **Sarvodaya Kanya Vidyalaya** at **West Patel Nagar, New Delhi-110008** from fire safety point of view in presence of **Mr. Paramjit Singh, Estate Manager** on dated **02/02/2026** During the course of inspection following observations were made:-

1. One stair found in block- B & block- D against requirement of two staircases having width of 1.50 mtrs. each.
2. First Aid hose reels found provided but not functional.
3. Terrace fire pumps capacity of 450 LPM (02 nos.) found provided but not functional in A block.
4. Exit Signs found removed at some places.

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

A.K.Malik
Dy.Chief Fire Officer

Copy to:-
1. SEEMA SRIVASTAVA , SARVODAYA KANYA VIDYALAYA, OPP.BLOCK NO-24, WEST PATEL NAGAR, DELHI, 110008
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.