GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

Application ID. 52026011900406 **Dated: 10-03-2026**

SHORTCOMING(S)

With reference to your application ID **52026011900406** dated **10-03-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **Modern International School** at **Sector- 19, Ph. 01, Dwarka, New Delhi- 110075** from fire safety point of view in presence of **Mr. A.K. Sinha** on dated **28/01/2026** During the course of inspection following observations were made:-

1. 3rd staircase found blocked/ closed at basement and upper floors level.
2. First aid hose reel provided but found not functional.
3. Terrace level fire pumps provided as per requirements but found not functional.
4. Overhead water storage tank of 10,000 ltrs found provided against requirement capacity of 15,000 ltrs.
5. Exit signage found removed at some places.
6. Basement is used for school activities shall be verified from the authority concerned.

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

A.K.Malik
Dy.Chief Fire Officer

Copy to:-
1. BHOLA NATH NIGAM , 107, NEAR C-BLOCK MARKET, EAST OF KAILASH, KAILASHHILLS SRINIWASPURI, DELHI, 110065
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.