GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

Application ID. 52026012100466 **Dated: 26-02-2026**

SHORTCOMING(S)

With reference to your application ID **52026012100466** dated **26-02-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **Carl Zeiss India Bangalore Private Limited** at **Plot No. A - 26/6, MCIE, New Delhi - 110044** from fire safety point of view in presence of **Mr. Rajiv Ahluwalia** on dated **31/01/2026** During the course of inspection following observations were made:-

1. First-Aid-Hose Reel provided but not functional.
2. Automatic Fire Detection and Alarm System provided but not functional.
3. MOEFA provided but not functional.
4. Automatic Sprinkler System provided but not functional.
5. Internal Hydrants provided but not functional.
6. Yard Hydrants provided but not functional.
7. Pumping arrangements provided but not functional.
8. Exit & floors Signage's not provided in strategic location in the building.

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

A.K.Malik
Dy.Chief Fire Officer

Copy to:-
1. Rajiv Ahluwalia , 507 , Paryatan Vihar, B-8, B-8 Near , Delhi, 110091
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.