GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

Application ID. 52026013000705 **Dated: 23-03-2026**

SHORTCOMING(S)

With reference to your application ID **52026013000705** dated **23-03-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **Cambridge School** at **A - Block, New Friends Colony, New Delhi - 110025** from fire safety point of view in presence of **Ms. Toposhi De** on dated **10/03/2026** During the course of inspection following observations were made:-

1.First Aid Hose Reel provided but not functional.
2.Automatic Sprinkler System provided but not functional.
3.Internal hydrant provided but not functional.
4.Terrace pump provided but not functional.
5.Exit & floors Signage's not provided in strategic location in the building.

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

A.K.Malik
Dy.Chief Fire Officer

Copy to:-
1. Anu Behl Roy , Cambridge Primary School, A Block , New Friends Colony, New Delhi, 110025
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.