GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

Application ID. 52026013000708 **Dated: 26-02-2026**

SHORTCOMING(S)

With reference to your application ID **52026013000708** dated **26-02-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **R. N. Memorial Public School** at **B-43, Shanti Nagar, Shiv Vihar, Delhi-110094** from fire safety point of view in presence of **Mr. Ved Prakash, Manager** on dated **19/02/2026** During the course of inspection following observations were made:-

1. First- aid Hose reels found removed.
2. A Terrace pump capacity 220 lpm head 40 meter found remvoed.
3. An overhead tank capacity 2,500 liters found removed.

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

Dr.S.K.Tomar
Dy.Chief Fire Officer

Copy to:-
1. Navneet Sharma , A Block, Gali No 16A, Adarsh Mohalla, Moujpur, 110094
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.