GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

Application ID. 52026013000711 **Dated: 07-03-2026**

SHORTCOMING(S)

With reference to your application ID **52026013000711** dated **07-03-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **Sirifort Institute of Management Studies** at **Sector-25, Rohini, Delhi-110085.** from fire safety point of view in presence of **Sh. Rakesh Kr. Baliyan (Admin Officer))** on dated **19/02/2026** During the course of inspection following observations were made:-

1. Hose reel hose is provided but not functional.
2. MOEFA system is provided but not functional.
3. Internal hydrant is provided but not functional.
4. Terrace level fire pumps is provided but not functional.
5. Exits & floors signage's found removed at strategical location in the premises.

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

S.K.DUA
Dy.Chief Fire Officer

Copy to:-
1. Rakesh Kumar , B64E, Garima Garden, Sahibabad, Sahibabad, 201005
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.