GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

Application ID. 52026022401196 **Dated: 07-04-2026**

SHORTCOMING(S)

With reference to your application ID **52026022401196** dated **07-04-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **Auditorium Building,** at **Chinmaya Mission, 89 Lodhi road, New Delhi 110003** from fire safety point of view in presence of **Sh. Umesh Mishra, PRO** on dated **21/03/2026** During the course of inspection following observations were made:-

1. Smoke management system in basement is not provided.
2. Hose reel found non- functional.
3. MOEFA found non-functional.
4. Automatic sprinkler system found non-functional.
5. Terrace pump found non-functional.
6. Auto starting of terrace pump found non-functional
7. Assembly occupancy found running in basement which is not regularized by NDMC.

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

A.K.Malik
Dy.Chief Fire Officer

Copy to:-
1. Jatinder Mohan Dhir , 68, , First Floor, Sukh Vihar, Delhi, 110051
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.