GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

Application ID. 52026022501225 **Dated: 23-05-2026**

SHORTCOMING(S)

With reference to your application ID **52026022501225** dated **23-05-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **MANKIND PHARMA LTD** at **Plot No 262, okhla Industrial Estate, Phase-III, New Delhi-110020.** from fire safety point of view in presence of **Sh. MD FAISAL** on dated **22/04/2026** During the course of inspection following observations were made:-

1. Width of internal road found encroached.
2. Pressurization of lift shaft found removed.

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

A.K.Malik
Chief Fire Officer

Copy to:-
1. MD FAISAL , FLAT NO 1409 14TH FLOOR , TOWER 12A , PURVANCHAL ROYA PARK, SECTOR 137 NOIDA, 201301
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.