GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

Application ID. 52026022701305 **Dated: 07-10-2026**

SHORTCOMING(S)

With reference to your application ID **52026022701305** dated **07-10-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **Swati Hostel** at **Mandir Marg, New Delhi** from fire safety point of view in presence of **Sh. Shailesh Jayant, PSS** on dated **24/08/2026** During the course of inspection following observations were made:-

1. Smoke Management System found removed in basement.
2. Public address system provided but found non-functional.
3. Automatic operation of Fire Pump found removed.

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

Dr.S.K.Tomar
Chief Fire Officer

Copy to:-
1. Narender Kumar Gaur , Room No. M001 NDMC, Palika Kendra, Sansad Marg, New Delhi, 110001
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.