GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

Application ID. 52026030901484 **Dated: 07-04-2026**

SHORTCOMING(S)

With reference to your application ID **52026030901484** dated **07-04-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **Guru Tegh Bahadur Public School** at **Gurudwara Siri Guru Singh Sabha, Lajpat Nagar - I, Krishna Market, New Delhi - 110024** from fire safety point of view in presence of **Mr. Ravinder Singh** on dated **24/03/2026** During the course of inspection following observations were made:-

1.Fire extinguisher provided but found empty.
2.First-Aid-Hose Reel at each floor provided but not functional.
3.Terrace level fire pump provided but not functional.
4.Overhead tank of 5000 liters capacity is provided against the requirement of 10,000 liters.
5.Exit & floors Signage's not provided in strategic location in the building.

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

A.K.Malik
Dy.Chief Fire Officer

Copy to:-
1. Ravinder Singh , 93, BLOCK E,, LAJPAT NAGAR 1,, DEFENCE COLONY, DELHI, 110024
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.