GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

Application ID. 52026032001747 **Dated: 16-04-2026**

SHORTCOMING(S)

With reference to your application ID **52026032001747** dated **16-04-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **Alka Public School** at **Hari Om Gali, Babarpur, Shahdara, Delhi** from fire safety point of view in presence of **Mrs. Neetu Jain, Principal** on dated **06/04/2026** During the course of inspection following observations were made:-

1. All water based system like Hose reel, Down-comer & Fire pump are found removed.
2. Overhead tank having capacity of 2,500 litres found removed.

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

Dr.S.K.Tomar
Dy.Chief Fire Officer

Copy to:-
1. Neetu Jain , H.No. 21/5A, Main Road Babarpur, Shahdara, Delhi, 110032
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.