GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

Application ID. 52026032401791 **Dated: 21-04-2026**

SHORTCOMING(S)

With reference to your application ID **52026032401791** dated **21-04-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **Hansraj Model School** at **Road No.-73, Punjabi Bagh, New Delhi-110026** from fire safety point of view in presence of **Sanjay Kalra, OSD** on dated **09/04/2026** During the course of inspection following observations were made:-

1. Staircase found blocked.
2. Fire extinguisher found missing at some locations.
3. Hose reel provided but found non functional.
4. Terrace pump not on auto mode.
5. Exit signage found missing at some locations.

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

S.K.DUA
Chief Fire Officer

Copy to:-
1. PRINCIPAL HANSRAJ MODEL SCHOOL , HANSRAJ MODEL SCHOOL, ROAD NO.73, PUNJABI BAGH, NEW DELHI, 110024
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.