GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

Application ID. 52026032401795 **Dated: 24-04-2026**

SHORTCOMING(S)

With reference to your application ID **52026032401795** dated **24-04-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **Sainik Model School** at **Plot No. -1/A-Block Extn., Vikas Nagar, New Delhi -110059** from fire safety point of view in presence of **Sh. Shekhar Jha** on dated **07/04/2026** During the course of inspection following observations were made:-

1. Some fire extinguishers found empty/un-refilled.
2. First-Aid Hose reel provided but found non-functional.
3. 450 LPM Fire provided but found non-functional.
4. Auto Starting found non-functional.
5. Overhead water storage tank found empty.

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

A.K.Malik
Chief Fire Officer

Copy to:-
1. K Shekhar Jha , A 14, Vikas Nagar Extn. , Uttam Nagar, New Delhi, 110059
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.