GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

Application ID. 52026032401809 **Dated: 24-04-2026**

SHORTCOMING(S)

With reference to your application ID **52026032401809** dated **24-04-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **New Evergreen Public School** at **C-138, Vikas Vihar, Bharat Vihar, Kakrola, New Delhi.** from fire safety point of view in presence of **Tarun Kumar** on dated **02/04/2026** During the course of inspection following observations were made:-

1. 02 Nos. staircases having width of 1.0 m up to terrace and 0.97 m up to 3rd floor provided against the requirement of width of 1.50 m each for ground to terrace level.
2. Width of classrooms door is 1.0 m at 2nd and 3rd floor instead of required width of 1.20 m.
3. First aid hose reel not provided at 2nd and 3rd floor.
4. Terrace pump capacity of 450 LPM is not provided.
5. Overhead Water Storage tank at terrace level capacity of 10,000 ltrs. exclusive for firefighting is not provided.
6. Exit Signage not Provided.
7. The Sanctioned building plan should be provided.

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

A.K.Malik
Chief Fire Officer

Copy to:-
1. Tarun Kumar , 21B, Kakraula Village, New Delhi, New Delhi, 110078
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.