GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

Application ID. 52026032801908 **Dated: 01-05-2026**

SHORTCOMING(S)

With reference to your application ID **52026032801908** dated **01-05-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **MRF Limited** at **22A, Shivaji Marg, Najafgarh Road, Near Moti Nagar, New Delhi 110015** from fire safety point of view in presence of **Mr. Ajeet John -Operational Manager** on dated **20/04/2026** During the course of inspection following observations were made:-

1. Fire check doors found removed.
2. Hose reel, Detectors, MOEFA, Internal Hydrant, Yard hydrant provided but found non functional.
3. All fire pumps provided but found non functional.
4. Exit Signage found removed.

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

S.K.DUA
Chief Fire Officer

Copy to:-
1. AJIT JOHN , 258, L AND T COLONY, SECTOR 18 B, DWARKA, 110078
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.