GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

Application ID. 52026041602263 **Dated: 23-09-2026**

SHORTCOMING(S)

With reference to your application ID **52026041602263** dated **23-09-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **Krishna Apartments Suraksha Sadan CGHS Ltd.** at **Plot No. 13, Sector- 09, Dwarka, Phase- 1, New Delhi- 110077.** from fire safety point of view in presence of **Mr. Wadhwa** on dated **02/09/2026** During the course of inspection following observations were made:-

1. Internal road all around the building found blocked/ encroached.
2. Hose reels provided but found not functional
3. MOEFA provided but found not functional.
4. Internal hydrant, Yard hydrant provided but found not functional.
5. Terrace level fire pump provided as per requirement but found not functional.
6. Exit Signs found removed at some places.

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

A.K.Malik
Chief Fire Officer

Copy to:-
1. ASHWANI KUMAR SAIGAL , 703, KRISHNA APARTMENT , PLOT NO. 13, SECTOR - 9, South West Delhi, 110077
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.