GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

Application ID. 52026042302439 **Dated: 24-07-2026**

SHORTCOMING(S)

With reference to your application ID **52026042302439** dated **24-07-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **Hostel Building IIFT, Institutional Complex and DG,s Residential Banglow** at **B-15, Qutab Institutional Area, Delhi** from fire safety point of view in presence of **Sh. Aman Kumar** on dated **16/07/2026** During the course of inspection following observations were made:-

1. Width of internal road is less than 06m.
2. Public address system found removed.
3. firemans grounding switch provided but not functional.

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

Sachin Rana, IAS
Pr. Director

Copy to:-
1. amit kumar chanpuriya , PLOT NO.118 GF-4 , VIDHAYAK KHAND, SHIPRA SUN CITY , GHAZIABAD, 201014
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.