GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

Application ID. 52026050602720 **Dated: 22-05-2026**

SHORTCOMING(S)

With reference to your application ID **52026050602720** dated **22-05-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **G.R.M. Public School** at **Kh. No. 88/23/2, Shiv Vihar, Karala, Delhi-110081** from fire safety point of view in presence of **Sh. Omparkash (Chairmen)** on dated **15/05/2026** During the course of inspection following observations were made:-

1. Some fire extinguisher is not functional.
2. Hose reel hose is provided but not functional and damaged condition.
3. Terrace level fire pump capacity of 450 LPM is provided but not functional and damaged condition.
4. Terrace level fire water tank capacity of 2000 Ltr is provided against the requirements of 10,000 Ltr.
5. Exits & floor signage's found removed at strategical location in the school premises.

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

S.K.DUA
Chief Fire Officer

Copy to:-
1. MANJU LATA , A-44, SHIV VIHAR VILLAGE, KARALA, DELHI, 110081
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.