GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

Application ID. 52026051202854 **Dated: 08-09-2026**

SHORTCOMING(S)

With reference to your application ID **52026051202854** dated **08-09-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **M/s Banarsidas Chandiwala Institute of Medical Sciences** at **J, K, H Block and Banarsidas Chandiwala Institute of Physiotherapy at Chandiwala Estate, Maa Anandmai Marg, Kalkaji, New Delhi-110019** from fire safety point of view in presence of **Dr C S Ram** on dated **14/08/2026** During the course of inspection following observations were made:-

1. First Aid Hose Reels provided but not functional.
2. MOEFA provided but found not functional.
3. In pumping arrangement Main fire fighting pump capacity of 1620 LPM , standby pump capacity of 1620 LPM and jockey pump- at ground level and terrace level pump capacity of 900 LPM, are provided but not on auto mode.
4. Exit signage found removed.

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

A.K.Malik
Chief Fire Officer

Copy to:-
1. Dr C S Ram , D-27/1 , Shyam Park Extension, Sahibabad, Ghaziabad, 201005
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.