GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

Application ID. 52026051602976 **Dated: 10-06-2026**

SHORTCOMING(S)

With reference to your application ID **52026051602976** dated **10-06-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **Rose Valley Public School** at **RZ - 20, Nathan Vihar, Nangloi-Najafgarh Road, Ranhola Village, New Delhi - 110041** from fire safety point of view in presence of **Sh. Prem Chand** on dated **01/06/2026** During the course of inspection following observations were made:-

1. Fire Extinguishers found provided but not functional.
2. First aid hose reel found provided but not functional.
3. Terrace level pump found provided but not functional.
4. Exit signages found removed at some places.

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

S.K.DUA
Chief Fire Officer

Copy to:-
1. PREM CHAND DESWAL , 591, EXCELLENCE APARTMENT, PLO, DWARKA SECTOR18A, , DELHI, 110075
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.