GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

Application ID. 52026052903267 **Dated: 09-09-2026**

SHORTCOMING(S)

With reference to your application ID **52026052903267** dated **09-09-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **New Merry Public School** at **A-6, Shish Ram Park, Uttam Nagar, New Delhi- 110059** from fire safety point of view in presence of **Sh. Deepak (Chairman)** on dated **04/08/2026** During the course of inspection following observations were made:-

1. One of the staircase having width of 1.0 m from ground floor to 1st floor & second staircase of 1.0 m from ground floor to terrace found provided against requirement of two staircases with width of 1.50 m each from ground floor to terrace level.
2. Hose reel found not provided.
3. Terrace fire pump of 180 LPM found provided against requirement of 450 LPM.
4. Overhead water storage tank capacity of 2,000 ltrs found provided against requirement capacity of 10,000 ltrs.
5. Exit signage's are not provided.

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

A.K.Malik
Chief Fire Officer

Copy to:-
1. Deepak Lamba , A-7, Shish Ram Park, Uttam, Nagar, 110059
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.