GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

Application ID. 52026061803768 **Dated: 23-07-2026**

SHORTCOMING(S)

With reference to your application ID **52026061803768** dated **23-07-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **Alok Bharti Public School** at **B-1, Sector-16, Rohini, Delhi-110085** from fire safety point of view in presence of **Ms. Samiksha Goel, Principal** on dated **15/07/2026** During the course of inspection following observations were made:-

1.Rear exit found blocked.
2.Some Fire extinguishers found empty.
3.Fire pump of 450 LPM found non-functional.
4.Overhead water storage tank is 5,000 ltrs. capacity provided against requirement of 10,000 ltrs.

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

S.K.DUA
Chief Fire Officer

Copy to:-
1. Samiksha Goel , 120, Paschim Enclave, Rohtak Road, New Delhi, 110087
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.