GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

Application ID. 52026061803772 **Dated: 03-08-2026**

SHORTCOMING(S)

With reference to your application ID **52026061803772** dated **03-08-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **Mata Sukhdevi Public School** at **G.T. Karnal Road, Nangli Poona, Delhi- 110036.** from fire safety point of view in presence of **Sh. Vishwanath Yadav** on dated **06/07/2026** During the course of inspection following observations were made:-

1. First aid hose reel found provided but not functional.
2. Terrace level pump found provided but not functional.
3. Overhead tank of 10,000 ltrs water storage capacity found empty.
4. Exit signage's found removed at some places.
5. School found running in Block 2 comprised of Ground and first floor (porta cabin) which is not permitted.

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

Sachin Rana, IAS
Pr. Director

Copy to:-
1. Msps , kh no 14/22 & 21, 14, Mata Sukhdevi School, DELHI, 110036
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.