GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

Application ID. 52026070104120 **Dated: 08-09-2026**

SHORTCOMING(S)

With reference to your application ID **52026070104120** dated **08-09-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **Atal Akshay Urja Bhawan** at **CGO Complex, Lodhi Road, New Delhi-03** from fire safety point of view in presence of **Vikas, JE Electrical, Deepak Yadav, JE Civil** on dated **19/08/2026** During the course of inspection following observations were made:-

1.Smoke management system not found integrated with MCPs/Detection system.
2.Portable fire extinguishers not found provided in Auditorium. Same shall be provided.
3.First aid hose-reels provided found non-functional at some locations & nozzle missing.
4.Automatic fire detectors found non-functional at some locations.
5.Manually operated electrical fire alarm found non-functional at some locations and not provided in Auditorium.
6.Automatic sprinkler system in basement found non-functional and light insufficient.
7.Fire pumps at ground level were not on auto mode.
8.Lift signage found missing at some places.
9.No trained fire officer was available/provided. Same shall be ensured/appointed in the interest of public/occupant safety at large.

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

A.K.Malik
Chief Fire Officer

Copy to:-
1. RAJAT YADAV , 280, NIMOTH, TEH, REWARI, 123411
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.