GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

Application ID. 52026070104130 **Dated: 12-08-2026**

SHORTCOMING(S)

With reference to your application ID **52026070104130** dated **12-08-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **SPS type Additional Classroom Block at Sarvodya Kanya Vidyalaya** at **Aram Bagh, Paharganj, New Delhi** from fire safety point of view in presence of **Smt. Manoj Kumari, Lecturer - Hindi** on dated **30/07/2026** During the course of inspection following observations were made:-

1. Hose Reels found damaged at some places.
2. Automatic operation of Fire Pump provided but found non-functional.
3. Lift Signages found removed.

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

Sachin Rana, IAS
Pr. Director

Copy to:-
1. PRIYANKA SINGH , SKV, ARAM BAGH LANE, PAHAR GANJ , DELHI, 110055
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.