GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

Application ID. 52026071404449 **Dated: 04-11-2026**

SHORTCOMING(S)

With reference to your application ID **52026071404449** dated **04-11-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **M & CW centre polyclinic** at **Fatehpur Beri in Ward No 72/south Zone, New Delhi-110074** from fire safety point of view in presence of **Mr Gaurav - JEE Elct.** on dated **09/10/2026** During the course of inspection following observations were made:-

1.First Aid Hose reels are provided but not functional.
2. Type of smoke detectors provided but not functional.
3.MOEFA provided but not functional.
4.Internal hydrants provided but not functional.
5.Yard hydrants provided but not functional.
6.Ground level pump discharge of 1620 LPM, Jockey pump out put 180 LPM, Standby Pump out put 1620 LPM are provided but not functional. Auto start stops not working.
7.Pressurization of lift shaft, lift lobby provided but not functional.

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

Sachin Rana, IAS
Pr. Director

Copy to:-
1. SHALINI MITTAL , M&CW centre fatehpur beri, main road near mallu farm, fatehpur beri village, new delhi, 110074
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.