GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

Application ID. 52026071504482 **Dated: 08-09-2026**

SHORTCOMING(S)

With reference to your application ID **52026071504482** dated **08-09-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **M/s Hero Corporate Pvt Ltd.** at **Plot No-264, okhla Industrial Area, Phase-III, New Delhi-110020** from fire safety point of view in presence of **Sh Ankit** on dated **12/08/2026** During the course of inspection following observations were made:-

1. Fire Check Door found removed at some places.
2. Overhead tank Capacity 10,000 ltrs provided against the requirements of 20,000 ltrs.

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

A.K.Malik
Chief Fire Officer

Copy to:-
1. Ankit , House no. 185, Pachenda Kalan, Pachenda Kalan , Muzaffarnagar, 251001
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.