GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

Application ID. 52026072004566 **Dated: 08-09-2026**

SHORTCOMING(S)

With reference to your application ID **52026072004566** dated **08-09-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **ESIC Hospital** at **Rohini, Sector-15, Delhi** from fire safety point of view in presence of **Sh. Sukhvinder** on dated **29/07/2026** During the course of inspection following observations were made:-

1.There are total 07 Staircases & 01 ramp communicating from ground to upper floors in the Hospital building out of which 01 staircase in admin area found permanently locked.

2.Fire check door found removed at some locations.

3.Natural Ventilated in some compartments found converted in to Air condition area without smoke management system.

4.First Aid Hose Reels provided but not reachable in all areas.

5.Internal/Yard Hydrant provided but found damaged at some locations and hose box found empty without deliver hose.

6.Communication in lift car & Fireman's grounding switch found non-functional.

7. Flow switch panel found removed

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

A.K.Malik
Chief Fire Officer

Copy to:-

1. Praveen Kumar Mishra , SG-02/1004, SAYAGOLD AVENUE VAIBHAV , KHAND , INDRAPURAM, 201014
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.