GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

Application ID. 52026072004574 **Dated: 08-09-2026**

SHORTCOMING(S)

With reference to your application ID **52026072004574** dated **08-09-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **M/s Ralson Remedies Pvt. Ltd.** at **J-38, Udyog Nagar, Industrial Area, Rohtak Road, Delhi-110041.** from fire safety point of view in presence of **Mr. Jitender** on dated **06/08/2026** During the course of inspection following observations were made:-

1.Fire check doors found removed at some placesComplied

2.Electrical panel inside the staircase has to be removed or been segregated with FCDNot Complied

3.The smoke ventilation system in the basement was found removed at some locationsNot Complied

4.The underground water storage tank having a capacity of 25,000 litres could not be inspected/verified as it was found sealed with cement.Not Complied

5. An Over Head Water Storage Tank having a capacity of 2,000 litres has been provided against the required capacity of 2,500 litres. Not Complied

6.Exit signage was found removed at some locations.Not Complied

7A terrace fire pump having a capacity of 450 LPM has been provided against the required capacity of 900 LPM. Further, a 180 LPM jockey pump has been provided.

8 The First Aid Hose Reel found removed in basement.

9 The open terrace area at the 1st floor was found covered with a tin shed.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form “J” with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form “J” are as under:

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

A.K.Malik
Chief Fire Officer

Copy to:-

1. RALSON REMEDIES PVT LTD , J-38, UDYOG NAGAR, ROHTAK ROAD, NEAR PEERA GARHI CHOWK, DELHI, 110041
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.