GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

Application ID. 52026072904761 **Dated: 11-09-2026**

SHORTCOMING(S)

With reference to your application ID **52026072904761** dated **11-09-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **Ansals Pragati Deep Building** at **Plot No. 08, District Centre, Laxmi Nagar, Deli 110092** from fire safety point of view in presence of **Sh. Kuldeep Saharan, DGM** on dated **19/08/2026** During the course of inspection following observations were made:-

1. The panic bar handle has been removed from the Fire Check Door (FCD).
2. Smoke Management System found removed in the basement and upper floors.
3. MOEFA is provided but not functional.
4. P.A. System is provided but not functional.
5. Pressurization of lift shaft found removed.
6. The designated refuge area has been encroached.

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

Dr.S.K.Tomar
Chief Fire Officer

Copy to:-
1. Ansal Housing Ltd , 2310, SECTOR14, SECTOR14, HISAR, 125001
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.