GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

Application ID. 52026073004786 **Dated: 08-09-2026**

SHORTCOMING(S)

With reference to your application ID **52026073004786** dated **08-09-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **Anusandhan CGHS Ltd.** at **Plot No. 22, Sector-06, Dwarka, New Delhi.** from fire safety point of view in presence of **Sh. Kanwalpreet Singh** on dated **14/08/2026** During the course of inspection following observations were made:-

1. Internal road all around the building found blocked/encroached by Car Parking and Plants.
2. Staircases found blocked at few places by plants pot.
3. First Aid hose reels provided but found not functional.
4. MOEFA and PA system provided but found not functional.
5. Internal and Yard hydrant provided but found not functional.
6. Terrace level Fire Pumps provided but found not functional.
7. Exit Signs found removed at some places.

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

A.K.Malik
Chief Fire Officer

Copy to:-
1. Kanwalpreet Singh , Wz 3 B 55 vishnu garden, Vishnu Garden, Vishnu Garden, Delhi, 110018
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.