GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

Application ID. 52026080304857 **Dated: 22-10-2026**

SHORTCOMING(S)

With reference to your application ID **52026080304857** dated **22-10-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **Conventional multilevel car parking** at **Krishna Market Kalkaji, New Delhi-110019** from fire safety point of view in presence of **Sh Rajiv Narang** on dated **16/09/2026** During the course of inspection following observations were made:-

1. Fire Check Door found removed at some places.
2. Smoke management system in basement Provided but not functional.
3. First Aid Hose reels are provided but not functional.
4. Type of detectors provided but not working.
5. MOEFA Provided but not functional.
6. Public Address system Provided but not functional.
7. Automatic Sprinkler system in basement Provided but not functional.
8. Internal hydrants Size of riser/down-comer- 150 mm, Provided but not functional and Hose box found removed.
09. Yard hydrants 10 nos Provided but not functional and Hose box found removed.
10. Ground level pump discharge of 2850 LPM x 2, Jockey pump out put 180 LPM X 2, Standby Pump out put 2850 LPM are Provided but not functional. Auto start stop not working.
11. Exit Signage Found removed.
12. Pressurization of lift shaft, lift lobby Provided but not functional.
13. Detector system panel, Flow switch panel, Pa system panel, Battery backup Provided but not functional.

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

Sachin Rana, IAS
Pr. Director

Copy to:-
1. RAJIV NARANG , Flat No 501, Tower Aster 6, , Supertech Emerald Court, , Sector 93A, NOIDA, 201304
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.