GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

Application ID. 52026080404875 **Dated: 19-10-2026**

SHORTCOMING(S)

With reference to your application ID **52026080404875** dated **19-10-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **M. C. Primary School** at **Wazirpur Ind. Area, A Block, New Delhi - 110052.** from fire safety point of view in presence of **Mr. Satish** on dated **05/10/2026** During the course of inspection following observations were made:-

1. Fire extinguishers provided but not functional.

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

Dr.S.K.Tomar
Chief Fire Officer

Copy to:-
1. MONIKA SHARMA , MCD PRIMARY SCHOOL, A BLOCK WAZIRPUR IND AREA, MCPS WAZIRPUR IND AREA A , DELHI, 110052
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.