GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

Application ID. 52026080504903 **Dated: 30-10-2026**

SHORTCOMING(S)

With reference to your application ID **52026080504903** dated **30-10-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **Govt. Boys Sr. Sec. School** at **Rajokari Near Shiv Mandir, New Delhi-38, School ID no. 1720028** from fire safety point of view in presence of **Sh. Suresh Yadav, Principal** on dated **22/09/2026** During the course of inspection following observations were made:-

1. Nozzle found removed in Hose reel Pipe.
2. Hose reel found non functional in New Block (G+3).
3. Fire Pump found non functional in New Block (G+3).

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

Sachin Rana, IAS
Pr. Director

Copy to:-
1. Suresh Chand Yadav , B-166 , Sector 8 , Dwarka , Dwarka , 110077
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.